SIEMENS

Data sheet

6EP1333-1LD00

SITOP PSU100D/1AC/24VDC/6.2A

PSU100D 24 V/6,2 A Stabilized power supply input: 100-240 V AC output: 24 V DC/6.2 A



Input	
type of the power supply network	1-phase AC
supply voltage at AC	
 minimum rated value 	100 V
 maximum rated value 	240 V
initial value	85 V
• full-scale value	264 V
design of input wide range input	Yes
operating condition of the mains buffering	at Vin = 115/230 V
buffering time for rated value of the output current in the event of power failure minimum	15 ms
operating condition of the mains buffering	at Vin = 115/230 V
line frequency	
• 1 rated value	50 Hz
2 rated value	60 Hz
line frequency	47 63 Hz
input current	
 at rated input voltage 100 V 	3.1 A
 at rated input voltage 240 V 	2 A
current limitation of inrush current at 25 °C maximum	75 A
I2t value maximum	6.5 A ² ·s
fuse protection type	internal
• in the feeder	Recommended miniature circuit breaker: from 10 A characteristic C or from 16 A characteristic B
Output	
voltage curve at output	Controlled, isolated DC voltage
output voltage at DC rated value	24 V
output voltage	
 at output 1 at DC rated value 	24 V
relative overall tolerance of the voltage	2 %
relative control precision of the output voltage	
 on slow fluctuation of input voltage 	0.5 %
 on slow fluctuation of ohm loading 	1 %
residual ripple	
• maximum	100 mV
voltage peak	
• maximum	100 mV
adjustable output voltage	22 28 V
product function output voltage adjustable	Yes
type of output voltage setting	via potentiometer

display version for normal operation	Groop LED for 24 V OK
display version for normal operation	Green LED for 24 V OK
behavior of the output voltage when switching on	Overshoot of Vout < 2 %
response delay maximum	1s
voltage increase time of the output voltage	20 mg
maximum	30 ms
output current	0.0 A
rated value	6.2 A
rated range	0 6.2 A; +50 +70 °C: Derating 2.5%/K
supplied active power typical	150 W
product feature	N/
bridging of equipment	Yes
number of parallel-switched equipment resources for increasing the power	2
Efficiency	
efficiency in percent	86 %
power loss [W]	
 at rated output voltage for rated value of the output current typical 	24 W
Closed-loop control	
relative control precision of the output voltage with rapid fluctuation of the input voltage by +/- 15% typical	0.5 %
relative control precision of the output voltage load step of resistive load 50/100/50 % typical	5 %
Protection and monitoring	
design of the overvoltage protection	< 35 V
response value current limitation typical	7.4 A
property of the output short-circuit proof	Yes
design of short-circuit protection	Electronic shutdown, automatic restart
enduring short circuit current RMS value	
• typical	16 A
display version for overload and short circuit	-
Safety	
	Yes
Safety	Yes Safety extra low output voltage Vout according to EN 60950-1
Safety galvanic isolation between input and output	
Safety galvanic isolation between input and output galvanic isolation	Safety extra low output voltage Vout according to EN 60950-1
Safety galvanic isolation between input and output galvanic isolation operating resource protection class	Safety extra low output voltage Vout according to EN 60950-1
Safety galvanic isolation between input and output galvanic isolation operating resource protection class leakage current	Safety extra low output voltage Vout according to EN 60950-1 Class I
Safety galvanic isolation between input and output galvanic isolation operating resource protection class leakage current • maximum	Safety extra low output voltage Vout according to EN 60950-1 Class I 3.5 mA
Safety galvanic isolation between input and output galvanic isolation operating resource protection class leakage current • maximum • typical	Safety extra low output voltage Vout according to EN 60950-1 Class I 3.5 mA 1 mA
Safety galvanic isolation between input and output galvanic isolation operating resource protection class leakage current • maximum • typical protection class IP	Safety extra low output voltage Vout according to EN 60950-1 Class I 3.5 mA 1 mA
Safety galvanic isolation between input and output galvanic isolation operating resource protection class leakage current • maximum • typical protection class IP Approvals	Safety extra low output voltage Vout according to EN 60950-1 Class I 3.5 mA 1 mA
Safety galvanic isolation between input and output galvanic isolation operating resource protection class leakage current • maximum • typical protection class IP Approvals certificate of suitability	Safety extra low output voltage Vout according to EN 60950-1 Class I 3.5 mA 1 mA IP20 Yes Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259;
Safety galvanic isolation between input and output galvanic isolation operating resource protection class leakage current • maximum • typical protection class IP Approvals certificate of suitability • CE marking	Safety extra low output voltage Vout according to EN 60950-1 Class I 3.5 mA 1 mA IP20 Yes Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259; cURus (UL 60950-1, CSA C22.2 No. 60950-1), File E151273 Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259;
Safety galvanic isolation between input and output galvanic isolation operating resource protection class leakage current • maximum • typical protection class IP Approvals certificate of suitability • CE marking • UL approval • CSA approval	Safety extra low output voltage Vout according to EN 60950-1 Class I 3.5 mA 1 mA IP20 Yes Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259; cURus (UL 60950-1, CSA C22.2 No. 60950-1), File E151273 Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259; cURus (UL 60950-1, CSA C22.2 No. 60950-1), File E151273 Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259; cURus (UL 60950-1, CSA C22.2 No. 60950-1), File E151273
Safety galvanic isolation between input and output galvanic isolation operating resource protection class leakage current • maximum • typical protection class IP Approvals certificate of suitability • CE marking • UL approval • CSA approval • cCSAus, Class 1, Division 2	Safety extra low output voltage Vout according to EN 60950-1 Class I 3.5 mA 1 mA IP20 Yes Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259; cURus (UL 60950-1, CSA C22.2 No. 60950-1), File E151273 Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259; cURus (UL 60950-1, CSA C22.2 No. 60950-1), File E197259; cURus (UL 60950-1, CSA C22.2 No. 60950-1), File E151273 No
Safety galvanic isolation between input and output galvanic isolation operating resource protection class leakage current • maximum • typical protection class IP Approvals certificate of suitability • CE marking • UL approval • CSA approval • CSAus, Class 1, Division 2 • ATEX	Safety extra low output voltage Vout according to EN 60950-1 Class I 3.5 mA 1 mA IP20 Yes Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259; cURus (UL 60950-1, CSA C22.2 No. 60950-1), File E151273 Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259; cURus (UL 60950-1, CSA C22.2 No. 60950-1), File E151273 Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259; cURus (UL 60950-1, CSA C22.2 No. 60950-1), File E151273
Safety galvanic isolation between input and output galvanic isolation operating resource protection class leakage current • maximum • typical protection class IP Approvals certificate of suitability • CE marking • UL approval • CSA approval • cCSAus, Class 1, Division 2 • ATEX certificate of suitability	Safety extra low output voltage Vout according to EN 60950-1 Class I 3.5 mA 1 mA IP20 Yes Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259; cURus (UL 60950-1, CSA C22.2 No. 60950-1), File E151273 Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259; cURus (UL 60950-1, CSA C22.2 No. 60950-1), File E151273 No No
Safety galvanic isolation between input and output galvanic isolation operating resource protection class leakage current • maximum • typical protection class IP Approvals certificate of suitability • CE marking • UL approval • CSA approval • cCSAus, Class 1, Division 2 • ATEX certificate of suitability • IECEx	Safety extra low output voltage Vout according to EN 60950-1 Class I 3.5 mA 1 mA IP20 Yes Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259; cURus (UL 60950-1, CSA C22.2 No. 60950-1), File E151273 Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259; cURus (UL 60950-1, CSA C22.2 No. 60950-1), File E151273 Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259; cURus (UL 60950-1, CSA C22.2 No. 60950-1), File E151273 No No No
Safety galvanic isolation between input and output galvanic isolation operating resource protection class leakage current • maximum • typical protection class IP Approvals certificate of suitability • CE marking • UL approval • CSA approval • cCSAus, Class 1, Division 2 • ATEX certificate of suitability • IECEx • NEC Class 2	Safety extra low output voltage Vout according to EN 60950-1 Class I 3.5 mA 1 mA IP20 Yes Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259; cURus (UL 60950-1, CSA C22.2 No. 60950-1), File E151273 Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259; cURus (UL 60950-1, CSA C22.2 No. 60950-1), File E151273 Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259; cURus (UL 60950-1, CSA C22.2 No. 60950-1), File E151273 No
Safety galvanic isolation between input and output galvanic isolation operating resource protection class leakage current • maximum • typical protection class IP Approvals certificate of suitability • CE marking • UL approval • CSA approval • cCSAus, Class 1, Division 2 • ATEX certificate of suitability • IECEx • NEC Class 2 • ULhazloc approval	Safety extra low output voltage Vout according to EN 60950-1 Class I 3.5 mA 1 mA IP20 Yes Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259; cURus (UL 60950-1, CSA C22.2 No. 60950-1), File E151273 Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259; cURus (UL 60950-1, CSA C22.2 No. 60950-1), File E151273 Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259; cURus (UL 60950-1, CSA C22.2 No. 60950-1), File E151273 No
Safety galvanic isolation between input and output galvanic isolation operating resource protection class leakage current • maximum • typical protection class IP Approvals certificate of suitability • CE marking • UL approval • CSA approval • cCSAus, Class 1, Division 2 • ATEX certificate of suitability • IECEx • NEC Class 2 • ULhazloc approval • FM registration	Safety extra low output voltage Vout according to EN 60950-1 Class I 3.5 mA 1 mA IP20 Yes Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259; cURus (UL 60950-1, CSA C22.2 No. 60950-1), File E151273 Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259; cURus (UL 60950-1, CSA C22.2 No. 60950-1), File E151273 Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259; cURus (UL 60950-1, CSA C22.2 No. 60950-1), File E151273 No
Safety galvanic isolation between input and output galvanic isolation operating resource protection class leakage current • maximum • typical protection class IP Approvals certificate of suitability • CE marking • UL approval • CSA approval • CCSAus, Class 1, Division 2 • ATEX certificate of suitability • IECEx • NEC Class 2 • ULhazloc approval • FM registration type of certification CB-certificate	Safety extra low output voltage Vout according to EN 60950-1 Class I 3.5 mA 1 mA IP20 Yes Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259; cURus (UL 60950-1, CSA C22.2 No. 60950-1), File E151273 Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259; cURus (UL 60950-1, CSA C22.2 No. 60950-1), File E151273 Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259; cURus (UL 60950-1, CSA C22.2 No. 60950-1), File E151273 No
Safety galvanic isolation between input and output galvanic isolation operating resource protection class leakage current • maximum • typical protection class IP Approvals certificate of suitability • CE marking • UL approval • CSA approval • CCSAus, Class 1, Division 2 • ATEX certificate of suitability • IECEx • NEC Class 2 • ULhazloc approval • FM registration type of certification CB-certificate certificate of suitability	Safety extra low output voltage Vout according to EN 60950-1 Class I 3.5 mA 1 mA IP20 Yes Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259; cURus (UL 60950-1, CSA C22.2 No. 60950-1), File E151273 Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259; cURus (UL 60950-1, CSA C22.2 No. 60950-1), File E151273 Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259; cURus (UL 60950-1, CSA C22.2 No. 60950-1), File E151273 No No </td
Safety galvanic isolation between input and output galvanic isolation operating resource protection class leakage current • maximum • typical protection class IP Approvals certificate of suitability • CE marking • UL approval • CSA approval • CCSAus, Class 1, Division 2 • ATEX certificate of suitability • IECEx • NEC Class 2 • ULhazloc approval • FM registration type of certification CB-certificate certificate of suitability • EAC approval	Safety extra low output voltage Vout according to EN 60950-1 Class I 3.5 mA 1 mA IP20 Yes Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259; cURus (UL 60950-1, CSA C22.2 No. 60950-1), File E151273 Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259; cURus (UL 60950-1, CSA C22.2 No. 60950-1), File E151273 No No No No No No No Yes Yes
Safety galvanic isolation between input and output galvanic isolation operating resource protection class leakage current • maximum • typical protection class IP Approvals certificate of suitability • CE marking • UL approval • CSA approval • CSA approval • CCSAus, Class 1, Division 2 • ATEX certificate of suitability • IECEx • NEC Class 2 • ULhazloc approval • FM registration type of certificate of suitability • EAC approval certificate of suitability	Safety extra low output voltage Vout according to EN 60950-1 Class I 3.5 mA 1 mA IP20 Yes Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259; cURus (UL 60950-1, CSA C22.2 No. 60950-1), File E151273 Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259; cURus (UL 60950-1, CSA C22.2 No. 60950-1), File E151273 Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259; cURus (UL 60950-1, CSA C22.2 No. 60950-1), File E151273 No No </td
Safety galvanic isolation between input and output galvanic isolation operating resource protection class leakage current • maximum • typical protection class IP Approvals certificate of suitability • CE marking • UL approval • CSA approval • cCSAus, Class 1, Division 2 • ATEX certificate of suitability • IECEx • NEC Class 2 • UL hazloc approval • FM registration type of certification CB-certificate certificate of suitability • EAC approval certificate of suitability • EAC approval certificate of suitability • EAC approval certificate of suitability shipbuilding approval	Safety extra low output voltage Vout according to EN 60950-1 Class I 3.5 mA 1 mA IP20 Yes Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259; cURus (UL 60950-1, CSA C22.2 No. 60950-1), File E151273 Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259; cURus (UL 60950-1, CSA C22.2 No. 60950-1), File E151273 No No No No No No Yes Yes Yes Yes Yes Yes Yes No Yes Yes Yes Yes
Safety galvanic isolation between input and output galvanic isolation operating resource protection class leakage current • maximum • typical protection class IP Approvals certificate of suitability • CE marking • UL approval • CSA approval • CSAus, Class 1, Division 2 • ATEX certificate of suitability • IECEx • NEC Class 2 • ULhazloc approval • FM registration type of certification CB-certificate certificate of suitability • EAC approval certificate of suitability • FM registration type of certification CB-certificate certificate of suitability • EAC approval certificate of suitability shipbuilding approval shipbuilding approval Marine classification association	Safety extra low output voltage Vout according to EN 60950-1 Class I 3.5 mA 1 mA IP20 Yes Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259; cURus (UL 60950-1, CSA C22.2 No. 60950-1), File E151273 Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259; cURus (UL 60950-1, CSA C22.2 No. 60950-1), File E151273 No No No No No Yes Yes Yes No No No No No No No No Yes Yes No -
Safety galvanic isolation between input and output galvanic isolation operating resource protection class leakage current • maximum • typical protection class IP Approvals certificate of suitability • CE marking • UL approval • CSA approval • cCSAus, Class 1, Division 2 • ATEX certificate of suitability • IECEx • NEC Class 2 • UL hazloc approval • FM registration type of certificate of suitability • EAC approval certificate of suitability shipbuilding approval	Safety extra low output voltage Vout according to EN 60950-1 Class I 3.5 mA 1 mA IP20 Yes Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259; cURus (UL 60950-1, CSA C22.2 No. 60950-1), File E151273 Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259; cURus (UL 60950-1, CSA C22.2 No. 60950-1), File E151273 No

• DNV GL	No
 Lloyds Register of Shipping (LRS) 	No
 Nippon Kaiji Kyokai (NK) 	No
EMC	
standard	
 for emitted interference 	EN 55022 Class B
 for mains harmonics limitation 	-
 for interference immunity 	EN 61000-6-2
environmental conditions	
ambient temperature	
 during operation 	-10 +70 °C; with natural convection
 during transport 	-40 +85 °C
 during storage 	-40 +85 °C
Mechanics	
type of electrical connection	screw-type terminals
● at input	L, N, PE: 1 screw terminal each for 0.3 1.3 mm ² single-core/finely stranded
 at output 	+, -: 2 screw terminals each for 0.3 1.3 mm ²
 for auxiliary contacts 	-
width of the enclosure	97 mm
height of the enclosure	178 mm
depth of the enclosure	38 mm
required spacing	
• top	20 mm
• bottom	0 mm
• left	20 mm
• right	20 mm
net weight	0.55 kg
fastening method	Wall mounting
other information	Specifications at rated input voltage and ambient temperature +25 °C (unless otherwise specified)

Ø